

CHARLES J. CONNICK : DESIGNER AND WORKER IN STAINED AND
LEADED GLASS : NINE HARCOURT STREET, BOSTON, MASSACHUSETTS

City or Town Nashua, State N.H. No. 2352
Date of Start May 11, 1942.
Church Universalist Church, Cor. Pearl & Main Sts. Completion
Donor and Wrote: Mr. Roland B. Burnham, Nashua Trust Co., Nashua, N.H.
Address

Quality of Glass See \$400 & \$500.
Architect _____ Glass \$590
Denomination Universalist.
and Minister _____

Footage About 9 feet wide and 12 feet high. sight
Sizes, full _____

Ventilators _____ Set by _____

Position in Church _____
Height from floor 9 feet Protec- Groove Stone
tion Glass _____ Rabbet _____ Wood _____
Points of compass _____
Quality of light _____

Inscription _____

Design wanted _____ Richard Holt, South Chestnut St.
Nashua. \$65.40

Shipping address _____ Blue-prints
Received

Bill to _____ Templets _____

Photos of Cartoons Mailed _____

General Information Repair. opalescent window, Christ and 12 Apostles.

Numerous obvious leaks between the glass and the lead, and whole window is
badly in need of re-cementing and puttying.

Scaffolding to be erected on outside, and whole window removed, straightened,
re-cemented and replaced.

We found frost on inside of window which may indicate condensation. A metal
condensation trough could be placed across the bottom of the window; but as
the glass comes to the sill, this condensation trough would interfere with
the view of the lower inch. Find out if they still want this.

For addresses of those to be notified as window progresses, see other side.